

## LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

6	1	A	L	J	M	F	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	9	LICENSEE CODE					14	LICENSE NUMBER										25	LICENSE TYPE					30	CAT 58			

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | At 1250 on 10/25/79, the containment air lock was declared inoperable due to a

03 | misaligned door interlock mechanism. Tech. Spec. 3.6.1.3 requires the containment air

04 | lock doors to be operable. Tech. Spec. 3.6.1.3 action statement requirements were

05 | met. The health and safety of the general public were not affected by this occurrence.

06 |

07 |

08 |

7 8 0

SYSTEM CODE 0 9		CAUSE CODE S D 11		CAUSE SUBCODE X 13		COMPONENT CODE P E N E T R 14		COMP. SUBCODE A 15		VALVE SUBCODE Z 16	
LER/RO REPORT NUMBER 17		EVENT YEAR 7 9 21 22		SEQUENTIAL REPORT NO. 0 4 7 24 25 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32	
ACTION TAKEN X 10 33		FUTURE ACTION Z 15 34		EFFECT ON PLANT Z 20 35		SHUTDOWN METHOD Z 21 36		HOURS 0 0 0 22 37 38 39 40		ATTACHMENT SUBMITTED N 23 41	
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27		PRIME COMP. SUPPLIER A 25 43		NPRD-4 FORM SUB. N 24 42		COMPONENT MANUFACTURER C 3 1 0 26 44 45 46 47					

1 0 This occurrence was attributable to a misaligned interlock mechanism. The interlock

1 1 was repaired, i.e. set screws tightened and bearings replaced, and the doors were

1 2 returned to service at 2130 on 10/25/79.

1 3

1 4

8 9 FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

1 5 G 78 0 0 0 29 NA A (31) Notification by C & HP personnel

7 8 9 ACTIVITY CONTENT 10 11 12 13 44 45 46 80

1 6 Z (33) Z (34) NA LOCATION OF RELEASE (36)

7 8 9 10 11 44 45 46 80

PERSONNEL EXPLOSIVES												
NUMBER			TYPE	DESCRIPTION								
1	2	0	0	0	37	Z	38	NA				

PERSONNEL INJURY NUMBER						DESCRIPTION	
1	8	0	0	0	(40)	NA	POOR ORIGINAL

LOS OF BIL DAMAGE TO FACILITY		TYPE		DESCRIPTION		NA		1388 118	
1	9	Z	(4)						

7911230 311 NRC USE ONLY

PHONE: (205) 899-5156

NHC USE ONLY