



435 Sixth Avenue
Pittsburgh, Pennsylvania
15219

(412) 456-6000

October 30, 1979

United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, PA 19406

ATTENTION: Mr. Boyce H. Grier

SUBJECT: Beaver Valley Power Station Unit No. 2
Docket No. 50-412, IE Bulletin No. 79-23,
titled Potential Failure of Emergency
Diesel Generator Field Excited Transformer


Gentlemen:

This letter responds to your letter of 9/12/79 that transmitted the subject IE Bulletin. We have determined the following:

1. There are no neutral connections between excitation or control power transformer primary windings and "high kVA rated" emergency diesel generators on Beaver Valley Power Station Unit No. 2. Therefore, no corrective action is needed.
2. The sustained full-load operation test of the emergency diesel generators that you require will be scheduled into the pre-operational testing of these generators.

We trust the above answers your questions.

DUQUESNE LIGHT COMPANY

By 
E. J. Woolever
Vice President

COPIES TO: Dr. V. Stello (15)
Mr. W. G. McDonald (1)

1389 160

373
7911280 