

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T
 D I 8
 M A P P S 1 2 0 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5
 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 31 CAT 32
 REPORT SOURCE I G 0 5 0 - 0 2 9 3 7 0 6 1 2 7 9 8 0 8 2 4 7 9 9
 DOCKET NUMBER 60 61 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During an IE Inspection it was discovered that on June 12, 1979 while performing
0 3 | repairs on the "A" core spray system minimum flow line, a degradation of primary
0 4 | containment occurred. When the minimum flow line check valve was removed, the
0 5 | TORUS was opened to atmosphere.

SYSTEM CODE S F (11)		CAUSE CODE A (12)		CAUSE SUBCODE A (13)		COMPONENT CODE V A L V E X (14)				COMP. SUBCODE C (15)		VALVE SUBCODE A (16)	
EVENT YEAR 7 9 (17)		SEQUENTIAL REPORT NO. 0 2 9 (18)		OCCURRENCE CODE 0 1 (19)		REPORT TYPE T (20)		REVISION NO. 0 (21)		ACTION TAKEN H (22)		FUTURE ACTION G (23)	
EFFECT ON PLANT Z (24)		SHUTDOWN METHOD Z (25)		HOURS 0 0 0 0 (26)		ATTACHMENT SUBMITTED Y (27)		PRD-4 FORM SUB. N (28)		PRIME COMP. SUPPLIER N (29)		COMPONENT MANUFACTURER V 0 8 5 (30)	

10 This event was caused by inadequate review of planned maintenance activities. This
11 incident will be reviewed, additional training conducted and procedures revised to
12 strengthen both procedural and management controls as described in the attached
13 letter to Mr. Boyce H. Grier.

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
5	E	28	1	0	0	29	N.A.	30	D	31	Result of IE Inspection 32			
ACTIVITY CONTENT			RELEASED OF RELEASE			AMOUNT OF ACTIVITY			N.A.			LOCATION OF RELEASE		
6	Z	33	Z	34		35	N.A.	36						
PERSONNEL EXPOSURES			NUMBER			TYPE			DESCRIPTION					
7	0	0	0	37	Z	38		39	N.A.					
PERSONNEL INJURIES			NUMBER			DESCRIPTION								
R	0	0	0	40		41			N.A.			90-356		
LOSS OF OR DAMAGE TO FACILITY			TYPE			DESCRIPTION								
9	Z	42				43			N.A.			7909050 518		
PUBLICITY			ISSUED			DESCRIPTION								
0	N	44				45			N.A.			NRC USE ONLY		

905356

7909050 5/8

NRC USE ONLY

NAME OF PREPARER Charles J. Mathis

PHONE: 617-746-7900