

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
THE HARTFORD ELECTRIC LIGHT COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

WILLIAM G. COUNSIL
VICE PRESIDENT
NUCLEAR ENGINEERING AND OPERATIONS

August 2, 1979

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region I
631 Park Avenue
King of Prussia, Pennsylvania 19406

ATTN: Mr. B. H. Grier, Director

Docket No. 50-423
AEC-MP3-190

Gentlemen:

SUBJECT: Millstone Unit No. 3
I.E. Bulletin No. 79-03

References: (1) B. H. Grier letter to W. G. Council dated March 12, 1979.
(2) W. G. Council letter to B. H. Grier dated May 15, 1979
(AEC-MP3-181).

In Reference (1) the subject I.E. Bulletin was transmitted to Northeast Nuclear Energy Company with appropriate action requested. A summary of the results of the investigation was transmitted to the NRC in Reference (2) noting that in several areas the investigation continued. A summary of the results of the investigation, now complete in all areas, can be found in Attachment 1 entitled Results of Investigation into NRC I.E. Bulletin 79-03.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in cursive script, reading 'W. G. Council'.

William G. Council
Vice President
Nuclear Engineering & Operations

Attachment

cc: Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, D. C. 20555

931310

7909100672

Results of Investigation into NRC. I.E. Bulletin 79-03

ATTACHMENT 1

<u>Vendor/Purchaser</u>	<u>System</u>	<u>Results/Comment</u>
1) Westinghouse	Reactor Coolant System	No welded pipe supplied by Youngstown Welding and Engineering Company used on this order.
2) Stone & Webster Construction Purchase Orders	Various - Safety Related Systems - Random Spools	No welded pipe supplied by Youngstown Welding and Engineering Company used on these orders.
3) Tubeco, Inc. (M-150)	Various - Safety Related Systems	Although substantial quantities of welded pipe from Youngstown Welding and Engineering Company has been or will be used in the fabrication of Unit 3 safety-related pipe spools, all of the material involved have had 100% x-ray of the longitudinal seam weld and therefore are considered acceptable.
4) Southwest Fabrication and Welding Company	Various - Safety Related Systems	Although quantities of welded pipe from Youngstown Welding and Engineering Company has been or will be used in the fabrication of Unit 3 safety-related pipe spools, all of the material involved have had 100% x-ray of the longitudinal seam weld and therefore are considered acceptable.
5) Miscellaneous Orders In Which Vendor May Have Supplied Pipe		No welded pipe of the type described in I.E. Bulletin 79-03 supplied by Youngstown Welding and Engineering Company used on these orders.

931311