

ATTACHMENT 2

NRC DOCKET 50-321
OPERATING LICENSE DPR-57
EDWIN I. HATCH NUCLEAR PLANT UNIT 1
PROPOSED CHANGES TO TECHNICAL SPECIFICATIONS

The proposed changes to the Technical Specifications (Appendix A to Operating License DPR-57) would be incorporated as follows:

Remove Page

3.5-5

Insert Page

3.5-5

943071

7909140237

3.5.B.3 Shutdown Requirements

If Specification 3.5.B.1.a or 3.5.B.2 cannot be met, the reactor shall be placed in the Cold Shutdown Condition within 24 hours.

3.5.C. RHR Service Water System1. Normal System Availability

The RHR service water system shall be operable:

- a. Prior to reactor startup from a Cold Condition, or
- b. When irradiated fuel is in the reactor vessel and the reactor vessel pressure is greater than atmospheric pressure except as stated in Specification 3.5.C.2.
- c. When irradiated fuel is in the reactor vessel and the reactor is depressurized at least one RHR service water loop shall be operable.

2. One Pump Inoperable

If one RHR service water pump is inoperable the reactor may remain in operation for a period not to exceed thirty (30) days provided all other active components of both subsystems are operable.

4.5.C. RHR Service Water System1. Normal System Availability

RHR service water system testing shall be performed as follows:

<u>Item</u>	<u>Frequency</u>
Pump Capacity Test: Each RHR service water pump shall deliver at least 4000 gpm at a system head of at least 847 feet.	After pump maintenance and once/3 months

943072