

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

0	1
---	---

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT D1

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

012 While in steady state operation at low power for tests after Startup, the Torus level
013 was being lowered. Plant personnel allowed Torus level to drop to 12 feet. Minimum
014 level per Tech Specs. 3.7.A.1.a is 12 feet 2 inches. Level was immediately restored
015 to normal limits. This did not cause any significant occurrence or have any effect on
016 public health or safety.

0 8		9		80	
0 9		SYSTEM CODE Z Z (11)		CAUSE CODE A (12)	
		CAUSE SUBCODE A (13)		COMPONENT CODE Z Z Z Z Z Z Z Z (14)	
				COMP. SUBCODE Z (15)	
				VALVE SUBCODE Z (16)	
(17) LER NO. REPORT NUMBER		EVENT YEAR 7 9		SEQUENTIAL REPORT NO. 0 7 1	
				OCCURRENCE CODE 0 3	
				REPORT TYPE L	
				REVISION NO. 0	
ACTION TAKEN H (18)		FUTURE ACTION Z (19)		EFFECT ON PLANT Z (20)	
		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 0 (22)	
				ATTACHMENT SUBMITTED N (23)	
				NPRD-4 FORMISUB N (24)	
				PRIME COMP. SUPPLIER Z (25)	
				COMPONENT MANUFACTURER Z 9 9 9 (26)	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 5 Torus level was being lowered by normal procedure. Plant personnel performing

1 1 Procedure failed to adequately monitor level decrease. After discovery, level was

1 2 immediately returned to within normal limits. Plant personnel have been reinstructed

1 3 to prevent reoccurrence.

1 4
7 8 9

FACILITY STATUS
1 5 C 28 0 2 1 29 NA 30

% POWER
1 5 C 28 0 2 1 29

OTHER STATUS 30 NA

METHOD OF DISCOVERY
A 31 Plant personnel observation 32

DISCOVERY DESCRIPTION 32 Plant personnel observation

ACTIVITY CONTENT
1 6 Z 33 Z 34

RELEASED OF RELEASE
1 6 Z 33 Z 34

AMOUNT OF ACTIVITY 35 NA

LOCATION OF RELEASE 36 NA

PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION 39
1 7 0 0 0 37 Z 38 NA

PERSONNEL INJURIES
NUMBER DESCRIPTION 41
1 8 0 0 0 40 NA

LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION 43
1 9 Z 42 NA

PUBLICITY
ISSUED DESCRIPTION 45
2 0 N 44 NA

948160
7000140346
NRC USE ONLY

NAME OF PREPARED BY S. X. Baxley

PHONE: (912) 367-6636