

**LICENSEE EVENT REPORT**

CONTROL BLOCK: 

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	P	V	S	1	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
7	8	LICENSEE CODE				14	LICENSE NUMBER										25	LICENSE TYPE					30	CAT				58

CON'T

0 1

REPORT SOURCE L 6 0 5 0 0 0 3 3 4 7 0 8 0 7 7 9 8 0 9 0 7 7 9 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During surveillance testing of the No. 1 Emergency Diesel Generator sequencing circuit,  
03 | the first loading sequence interval was 4.106 seconds rather than the required 4.500  
04 | seconds. The health and safety of the general public was not jeopardized since the  
05 | diesel generator is capable of accepting full load in 3.5 seconds as demonstrated by  
06 | the manufacturer's 150 test runs. Therefore, the diesel generator is capable of  
07 | accepting partial load at 4.1 seconds.  
08 |

09		SYSTEM CODE EE		CAUSE CODE E		CAUSE SUBCODE B		COMPONENT CODE INSTRU						COMP. SUBCODE C		VALVE SUBCODE Z													
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24												
LER/RO REPORT NUMBER		EVENT YEAR 79		SEQUENTIAL REPORT NO. 031		OCCURRENCE CODE 03		REPORT TYPE L		REVISION NO. 0		ACTION TAKEN E		FUTURE ACTION Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0000		ATTACHMENT SUBMITTED N		NPRD-4 FORM SUB. N		PRIME COMP. SUPPLIER A		COMPONENT MANUFACTURER E147	
25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The short first interval resulted because the starting point of the sequencer was

1 1 | slightly off zero. The sequencer was cycled and adjusted to within specifications.

1 2 |

1 3 |

1 4 |

7 8 9

FACILITY STATUS		% POWER			OTHER STATUS	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION					
1	5	G	28	0	0	0	29	N/A	B	31	Surveillance test	32
7	8	9	10	11	12	13	14	15	16	17	18	19

ACTIVITY CONTENT  
RELEASED OF RELEASE

1 6 2 33 2 34 N/A

7 8 9 10 11 44

AMOUNT OF ACTIVITY (35)

LOCATION OF RELEASE (36)

N/A

45 80

PERSONNEL EXPOSURES				DESCRIPTION	
NUMBER		TYPE			
1	7	000	Z	(38)	N/A

PERSONNEL INJURIES									
NUMBER				DESCRIPTION					
1	8	0	0	0	40	N/A			

ORIGINAL

949207

1		9		2		42		N/A		7909140374	
---	--	---	--	---	--	----	--	-----	--	------------	--

PUBLICITY		ISSUED		DESCRIPTION		NRC USE ONLY									
	(45)	2	0	N	(14)	N/A									

NAME OF PREPARER J. A. Werling

PHONE: 412-643-1258

NRC USE ONLY