


LICENSEE EVENT REPORT

CONTROL BLOCK: 

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	A	P	P	S	1	2	0	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4			5		
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

REPORT SOURCE L 6 0 5 0 - 0 2 9 3 7 0 8 2 8 7 9 9 B 0 9 1 1 7 9 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On August 18, 1979 at 0030 hrs, a reactor scram occurred as a result of a loss of
0 3 | all off-site power. The emergency diesel generators functioned as required and
0 4 | assumed emergency loads. A relief valve was manually actuated to control pressure
0 5 | and maneuver the reactor to a safe shutdown.
0 6 |
0 7 |
0 8 |

09		SYSTEM CODE E A 11		CAUSE CODE C 12		CAUSE SUBCODE Z 13		COMPONENT CODE Z Z Z Z Z Z 14						COM. SUBCODE Z 15		VALVE SUBCODE Z 16	
7 8		9 10		11 12		13 14		15 16 17 18						19 20			
17		EVENT YEAR 7 9 21 22		SEQUENTIAL REPORT NO. 0 3 3 24 25 26		OCCURRENCE CODE 0 1 28 29		REPORT TYPE T 30		REVISION NO. 0 32							
ACTION TAKEN X 18 33		FUTURE ACTION X 19 34		EFFECT ON PLANT A 20 35		SHUTDOWN METHOD C 21 36		HOURS 0 0 1 2 22 37 38 39 40		ATTACHMENT SUBMITTED N 23 41		NPRD-4 FORM SUB. N 24 42		PRIME COMP. SUPPLIER Z 25 43		COMPONENT MANUFACTURE Z 9 9 9 44	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (2)

1 0 The cause of this event was lightning striking the station switchyard causing a
1 1 high speed relay operation for a line to ground fault. Power was restored to the
1 2 startup transformer and station loads returned to normal after approximately 30
1 3 minutes.
1 4
2 8 9 949254

FACILITY STATUS				% POWER				OTHER STATUS				METHOD OF DISCOVERY				DISCOVERY DESCRIPTION			
1	5	E	(28)	1	0	0	(29)	N.A.				A	(31)	Operational Event					
ACTIVITY CONTENT				AMOUNT OF ACTIVITY				LOCATION OF RELEASE											
1	6	Z	(33)	Z	(34)	N.A.				N.A.									
PERSONNEL EXPOSURES				DESCRIPTION															
1	7	0	0	0	(37)	Z	(38)	N.A.											
PERSONNEL INJURIES				DESCRIPTION															
1	8	0	0	0	(40)	N.A.													
LOSS OF OR DAMAGE TO FACILITY				DESCRIPTION															
1	9	Z	(42)	N.A.								7909140394.							
PUBLICITY				DESCRIPTION								NRC USE ONLY							
2	0	N	(44)	N.A.															

NAME OF PREPARER John M. Fulton

PHONE: _____

NRC USE ONLY

617-746-7900