

THE CINCINNATI GAS & ELECTRIC COMPANY



E. A. BORGMANN
VICE PRESIDENT

August 22, 1979
QA-1189

U. S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. J. G. Keppler,
Director

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT I
IE INSPECTION REPORT NO. 79-06, CONSTRUCTION
PERMIT NO. CPPR-88, DOCKET NO. 59-358,
W.O. #57300-957, JOB E-5590

Gentlemen:

This letter supplements our formal reply to the subject inspection report. It is our opinion that nothing in this letter is proprietary in nature.

We wish to supplement the Corrective Action to be Taken to Avoid Further Noncompliance portion of the reply to Item 1a as follows:

Procedures SU.ACP.02, Preparation of Flushing Procedures, and SU.ACP.03, Conduct of Flushing, are being modified to transfer responsibility for verification of boundary valve position and tagging from the General Engineering Department QA&S Section to the Electric Production Department QC Group. This change will vest responsibility for the entire flushing program within one department.

The Electric Production Department Quality Engineer will establish witness points on the initial valve line-up in the "official" copy of flushing procedures which have not been started, and, as appropriate on documented deviations to flushing procedures.

The QA&S Section will perform audits to assure that these commitments are fulfilled.

1152 074

7910160 204
AUG 27 1979

Mr. J. G. Keppler, Director
U. S. Nuclear Regulatory Commission
Region III
QA-1189 - August 22, 1979
Page 2

Date When Full Compliance will be Achieved


Full compliance to this procedure will be achieved by
September 1, 1979.

We trust that you will find this supplement acceptable.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By



E. A. BORGMANN
SENIOR VICE PRESIDENT

RLW:pa

1152 075