



**Consumers
Power
Company**

Stephen H. Howell
Senior Vice President

General Offices: 1945 West Parnall Road, Jackson, Michigan 49201 • (517) 788-0453

October 12, 1979
Howe-265-79

Mr J G Keppler, Regional Director
Office of Inspection and Enforcement
US Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

MIDLAND NUCLEAR PLANT
UNIT NO 1, DOCKET NO 50-329
UNIT NO 2, DOCKET NO 50-330
DROP-IN ANCHORS

Reference: S H Howell letter to J G Keppler; Midland Nuclear Plant;
Unit No 1, Docket No 50-329; Unit No 2, Docket No 50-330;
Drop-In Anchors; Serial Howe-247-79; dated September 12, 1979

In accordance with the requirements of 10 CFR 50.55(e), this letter constitutes the second interim report on the status of Hilti Drop-In Anchors which did not meet the tension testing requirements.

The reference provided a description of the discrepancy and the potential safety implications. The attachment provides an updated status of the investigation and corrective action.

Another report, either interim or final, will be sent on or before December 21, 1979.

Stephen H. Howell

WRB/lr

Attachment: Status of Investigation and Corrective Action for MCAR 34
(Drop-In Anchors), dated October 3, 1979.

CC: Director of Office of Inspection & Enforcement
Att: Mr Victor Stello, USNRC (15)

Director, Office of Management
Information and Program Control, USNRC (1)

1157 151

7910160 344