



Docket No. 50-346  
License No. NPF-3  
Serial No. 541

LOWELL E. ROE  
Vice President  
Facilities Development  
(419) 259-5242

October 3, 1979

Director of Nuclear Reactor Regulation  
Attention: Mr. Robert N. Reid, Chief  
Operating Reactors Branch No. 4  
Division of Operating Reactors  
United States Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Mr. Reid:

Under separate cover, we are transmitting three (3) original and forty (40) conformed copies of an application for amendment to Facility Operating License No. NPF-3 for the Davis-Besse Nuclear Power Station Unit No. 1.

This application requests that the Davis-Besse Nuclear Power Station Unit No. 1 Technical Specifications be revised as described below. The proposed changes in Appendix A include: 1) deletion of secondary water chemistry specifications in Sections 3.7.1.6 and 4.7.1.6 of the Technical Specifications; and 2) add the proposed license condition 2.(F) regarding implementation of a secondary water chemistry monitoring program.

This amendment request is a Class III request. Enclosed is \$4,000.00 as required by 10CFR170.

The attachment identifies the proposed change, its safety evaluation and schedule required to implement the change after NRC approval.

Yours very truly,

Enclosure

bj c/9

1153 222

P 7910160366

APPLICATION FOR AMENDMENT  
TO  
FACILITY OPERATING LICENSE NO. NPF-3  
FOR  
DAVIS-BESSE NUCLEAR POWER STATION  
UNIT NO. 1

Enclosed are forty-three (43) copies of the requested change to the Davis-Besse Nuclear Power Station Unit No. 1 Facility Operating License No. NPF-3 together with the safety evaluation for the requested change. The proposed changes include 1) deletion of the secondary water chemistry specifications in Sections 3.7.1.6 and 4.7.1.6 of the Technical Specifications; and 2) add the proposed license condition 2.(F) regarding the implementation of a secondary water chemistry monitoring program.

By Lowell P. Roe  
Vice President, Facilities Development

Sworn to and subscribed before me this third day of October 1979.

William L. Windnagle  
Notary Public

WILLIAM L. WINDNAGLE  
Notary Public, State of Ohio  
My Commission Expires October 24, 1980

1153 223

PROPOSED LICENSE CONDITION

- 2.(F) Toledo Edison Company shall maintain in effect and implement a secondary water chemistry monitoring program to inhibit steam generator tube degradation. The program shall include:
1. Identification of a sampling schedule for the critical parameters and control points for these parameters;
  2. Identification of the procedures used to quantify parameters that are critical to control points;
  3. Identification of process sampling points;
  4. Procedure for the recording and management of data;
  5. Procedures defining corrective actions for off control point chemistry conditions; and
  6. A procedure identifying the authority responsible for the interpretation of the data, and the sequence and timing of administrative events required to initiate corrective action.

1153 221