

**LICENSEE EVENT REPORT**

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | C 0 F S V | 1 | 2 | 0 0 - 0 0 0 0 0 0 - 0 0 | 3 | 4 1 1 2 0 | 4 | 5 |

7 8 9 14 15 25 26 30 57 CAT 58

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T

REPORT SOURCE: 01 L6 050002677 0910798 1010799

DOCKET NUMBER: 60 61 68 69 74 75 80

EVENT DATE: 68 69 74 75 80

REPORT DATE: 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On September 10, 1979, with reactor shutdown, cold reheat snubber CRS-262 was observed

0 3 | to be missing a pin at the piston rod eye, and was thus inoperable. This is operation

0 4 | in a degraded mode of LCO 4.3.10 and is reportable per Fort St. Vrain Technical Speci-

0 5 | fication AC 7.5.2(b)2. No affect on public health or safety.

0 6 |

0 7 |

0 8 |

7 8 9

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22		
		Z	Z	E	B	S	U	P	O	R	T	D	Z				
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
23	24	25	26	27	28	29	30	31	32	33	34						
		7	9	0	3	6	/	0	3	L	0						
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52
A	X	Z	Z					0	0	0	0	Y	N	A	I	2	0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 One cold rehear snubber was inoperable due to a missing piston rod eye pin. A new

1 1 pin was fabricated and installed. The surveillance interval is presently 12 months

1 2  $\pm$  25%. No adjustment is required.

1 3

1 4

7 8 9

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

FACILITY STATUS (28) G % POWER (29) 0 0 0 OTHER STATUS (30) N/A METHOD OF DISCOVERY (31) A DISCOVERY DESCRIPTION (32) Personnel Observation

ACTIVITY CONTENT RELEASED OF RELEASE (33) Z (34) Z N/A AMOUNT OF ACTIVITY (35) N/A LOCATION OF RELEASE (36) N/A

PERSONNEL EXPOSURES										
NUMBER			TYPE	DESCRIPTION (39)						
1	7	0	0	0	(37)	Z	(38)	N/A		

7	8	9	11	12	13	80
PERSONNEL INJURIES						
NUMBER		DESCRIPTION (41)				
						1154 143

1	8	0	0	0	(40)	N/A
7	8	9	11	12		

LOSS OF OR DAMAGE TO FACILITY (43)

TYPE	DESCRIPTION

1	9	Z	(42)	N/A
7	8	9	10	

PUBLICITY  
ISSUED **N** (44) DESCRIPTION (45) **7910160** 417  
2 0 N/A  
7 8 9 10 68 69 70 71 72 73 74 75 76 77 78 79 80  
NRC USE ONLY

NAME OF PREPARER

J. W. Gahm

PHONE: (303) 785-2253

NRC USE ONLY

7910160 417

1154 143