



Houston Lighting & Power Company

Electric Tower
P.O. Box 1700
Houston, Texas 77001

October 9, 1979
ST-HL-AE-381
SFN: V-0100

Director, Region IV
Office of Inspection and Enforcement
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76102

Dear Sir:

South Texas Project
Units 1 & 2
Docket Nos. STN 50-498, STN 50-499
Final Report on the Essential
Cooling Water Intake Structure
Gantry Crane

On May 16, 1979, Houston Lighting & Power Company reported to your office the failure to properly include the effects of tornado wind loadings on the essential cooling water gantry crane. This transmittal provides a final written report as required by 10 CFR 50.55(e).

Very truly yours,

E. A. Turner
Vice President
Power Plant Construction
& Technical Services

LRJ:bf
Attachment

1154 285

Bo19
5/11

7910160455

cc: D. G. Barker
A. J. Granger
R. A. Frazar
M. D. Schwarz (Baker & Botts)
R. Gordon Gooch (Baker & Botts)
J. R. Newman (Lowenstein, Newman, Reis, Axelrad & Toll)
Director, Office of Inspection & Enforcement✓
Nuclear Regulatory Commission
Washington, D.C. 20555

Charles Bechhoefer, Esquire
Chairman, Atomic Safety & Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dr. James C. Lamb, III
313 Woodhaven Road
Chapel Hill, North Carolina 27514

Dr. Emmeth A. Luebke
Atomic Safety & Licensing Commission
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Steven A. Sinkin, Esquire
116 Villita Street
San Antonio, Texas 78205

Citizens for Equitable Utilities
c/o Ms. Peggy Buchorn
Route 1, Box 432
Brazoria, Texas 77422

Richard W. Lowerre, Esquire
Assistant Attorney General for the State of Texas
P. O. Box 12548
Capitol Station
Austin, Texas 78711

Henry J. McGurren, Esquire
Hearing Attorney
Office of the Executive Legal Director
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

1154 286