POOR ORIGINAL

NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | S C N E E 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 7 0 (7) | 0 9 2 4 7 9 (8) | 1 0 1 0 7 9 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 The RB gaseous radiation monitors were rendered inoperable when a containment
03 isolation valve on the monitors' return line failed closed. The valve was
04 repaired and the monitors were returned to service well within the times
05 allowed by Technical Specifications 3.1.6.8 and 3.6.3. In addition, two
06 other means for detecting RCS leakage were available. Therefore, this incident
07 was of no significance with respect to safe operation, and the health and
08 safety of the public were not endangered.

09 SYSTEM CODE B B (11) | CAUSE CODE E (12) | CAUSE SUBCODE F (13) | COMPONENT CODE V A L V E X (14) | COMP. SUBCODE D (15) | VALVE SUBCODE D (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 | — | SEQUENTIAL REPORT NO. 0 0 5 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN A (18) | FUTURE ACTION G (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED Y (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER L (25) | COMPONENT MANUFACTURER I 2 0 7 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The valve failed due to a hole in its operator diaphragm, which is believed
11 to have exceeded its expected service life. The diaphragm was replaced, and
12 the valve was tested to verify operability. The preventive maintenance pro-
13 gram will be revised to review ES valves to identify those with diaphragms
14 needing replacement.

15 FACILITY STATUS E (28) | % POWER 0 9 2 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Routine ES valve test

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES
18 NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

1149 004

LOSS OF OR DAMAGE TO FACILITY (43)
19 TYPE Z (42) | DESCRIPTION NA

PUBLICITY
20 ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY

7910170 247

NAME OF PREPARER S. R. Lewis PHONE: (704) 373-8285