

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5			
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58		59

CON'T

0	1																														
7	8																														

REPORT SOURCE

L	6	0	5	0	-	0	3	2	4	7	1	0	3	1	7	9	8																			
60	61	DOCKET NUMBER										68	69	EVENT DATE										74	75	REPORT DATE										80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While trying to run the containment atmospheric monitor 2-CAC-AQH-1259, the operator

03 | could not get the monitor to run for more than a few minutes at a time. Low sample

04 | flow was also noted at this time.

0	5	
---	---	--

0	6	
---	---	--

0	7	
---	---	--

08 Technical Specifications 3.3.5.3, 6.9.1.9b

7 8 9 10 11 12 13 14 15 16

(17) LER/RO REPORT NUMBER [7 9] [—] [0 9 0] [/] [0 3] [L] [—] [0]
 21 22 23 24 25 26 27 28 29 30 31 32

ACTION TAKEN 33 A 34 X 35 Z 36 Z 37 0 38 0 39 0 40 0 41 Y 42 Y 43 A 44 A 45 4 46 9 47 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	A failure of the condensate drain pot solenoid valve caused condensation to back up
---	---	---

11 into the air sample lines blocking the sample flow. The solenoid valve was replaced

1 2 and the system was returned to service satisfactorily. A check was made of the other

13 monitors with no problem found. While this investigation was being conducted, it was

1 4 determined that a section of piping from the suppression pool sample line formed a

FACILITY STATUS			% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	0	9	1	N/A	A	Operator Surveillance		

ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE	
1	6	2	33	34	N/A	35	36

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	(37)	Z	(38)	N/A		

PERSONNEL INJURIES		DESCRIPTION (41)	
NUMBER		DESCRIPTION	
1	0	0	(40) N/A

POOR ORIGINAL

7 8 9 10 11 12
LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION

1443 060

PUBLICITY
 ISSUED DESCRIPTION (45)
 20 N (44) N/A
 7911300 608
 NRC USE ONLY

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919 - 457-9521

NRC USE ONLY

7911300 608

1443 060

LER CONTINUATION - RO #2-79-90

FACILITY: Unit #2

EVENT DATE: 10-31-79

- small loop below the monitor which could fill with condensate and block sample flow. An Engineering Work Request was initiated to correct this problem.

1443 061