

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M D C C 11 00 - 000000 - 000 411111 4 5
 7 8 9 14 15 25 26 30 37 CAT 38

01 REPORT SOURCE 1050000311771111479 1120479 9
 7 8 9 60 61 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

02 While 500kv breaker 552-41 was open, breaker 552-43 tripped and the
 03 500kv transmission line 5052 was deenergized. The transmission line
 04 was out of service for ten minutes until Maintenance personnel determined
 05 that there was no fault and the breaker (552-43) was closed. This is not
 06 a repetitive occurrence. (T.S. 3.8.1.1)
 07
 08

09 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
 7 8 9 10 11 12 13 14 15 16
 EA X Z Z Z Z Z Z Z Z Z
 17 LER NO. REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
 7 8 9 21 22 23 24 25 26 27 28 29 30 31 32
 79 072 03 L 0
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRC-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
 33 34 35 36 37 40 41 42 43 44 47
 Z Z Z Z 0000 N N Z Z 9999

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

10 Electric Test personnel inspected the static line relay panel subsequent
 11 to the inspection by Electric System Operation personnel. Both
 12 inspections revealed no apparent reason for the breaker trip; however,
 13 Electric Test personnel were working on that relay panel and may have
 14 inadvertently caused the breaker trip during their inspection.

15 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
 7 8 9 10 11 12 13 14 15 16
 E 050 N/A Z N/A
 16 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
 7 8 9 10 11 12 13 14 15 16
 Z Z N/A N/A

17 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
 7 8 9 10 11 12 13
 000 Z N/A

18 PERSONNEL INJURIES NUMBER DESCRIPTION
 7 8 9 10 11 12
 000 N/A

19 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
 7 8 9 10 11 12
 Z N/A

20 PUBLICITY ISSUED DESCRIPTION
 7 8 9 10 11 12
 N N/A

NAME OF PREPARER R. P. Heibel

PHONE (301) 234-7943

POOR ORIGINAL

1506 233

7912060 499

NRC USE ONLY