

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

December 10, 1979

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. A. Schwencer, Chief
Operating Reactors Branch No. 1
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Serial No. 992

LQA/WRM:shs

Docket No. 50-338

License No. NPF-4

Dear Mr. Denton:

MODIFICATION TO AMENDMENT TO OPERATING LICENSE NPF-4
NORTH ANNA POWER STATION UNIT NO. 1
TECHNICAL SPECIFICATION CHANGE NO. 23

By a letter dated October 25, 1979, we requested a change to the Technical Specifications for North Anna Power Station Unit No. 1. These changes were designated as Proposed Technical Specification Change No. 23. It has come to our attention that a modification to our original change proposal is needed.

FSAR Section 3.1.49 and 10CFR50 Appendix A, Criterion 56.4 require one automatic valve inside and one automatic valve outside the containment for isolation. 1-IA-55 is a check valve and qualifies as an automatic valve inside the containment. Since TV-IA-102B is the closest automatic valve to the containment, it is the automatic valve outside the containment. These two valves together form the isolation boundary and therefore must be listed in Table 3.6-1. Valve TV-102A will not serve as an isolation valve, and should not be included in the table.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the System Nuclear Safety and Operating Committee. It has been determined that this request does not pose an unreviewed safety question, as defined in 10CFR50.59.

1536 351

7912120 449 P

We have evaluated this request in accordance with the criteria in 10CFR170.22. Since this request is a modification of a proposed change which is currently under your review, an additional amendment fee is not necessary.

Very truly yours,

C. M. Stallings

C. M. Stallings
Vice President-Power Supply
and Production Operations

Attachment

1. Replacement pages 3/4 6-22 and 3/4 6-29 for
Proposed Technical Specification Change No. 23

cc: Mr. James P. O'Reilly, Director
Office of Inspection and Enforcement
Region II

1536 552

COMMONWEALTH OF VIRGINIA)
) S. S.
CITY OF RICHMOND)

Before me, a Notary Public, in and for the City and Commonwealth aforesaid, today personally appeared C. M. Stallings, who being duly sworn, made oath and said (1) that he is Vice President-Power Supply and Production Operations, of the Virginia Electric and Power Company, (2) that he is duly authorized to execute and file the foregoing Amendment in behalf of that Company, and (3) that the statements in the Amendment are true to the best of his knowledge and belief.

Given under my hand and notarial seal this 10th day of December, 1931.

My Commission expires January 20, 1931.

Robert M. Nail
Notary Public

(SEAL)

1536 353