



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street - Suite 3100  
Atlanta, Georgia 30303

September 5, 1979

ATTENTION: Mr. J. P. O'Reilly, Director

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
File 0270/15521/15525  
Interim Report No. 2 for PRD 79/03  
As Defined in 10 CFR 50.55(e)  
AECM-79/100

On February 12, 1979, Mississippi Power & Light Company notified Mr. J. K. Rausch of your office of a potential reportable deficiency at the Grand Gulf Nuclear Station construction site. The deficiency concerns General Electric's failure to establish and implement an approved Quality Assurance Program for electrical work performed under Field Deviation Disposition Requests (FDDR) and Field Deviation Instructions (FDI).

An upgraded I&SE Quality Assurance Manual for electrical and electronics at Grand Gulf has been approved. The subject electrical work is being reinspected in accordance with the manual. We expect to issue a final report on this matter by January 31, 1980.

Yours truly,

L. F. Dale  
Nuclear Project Manager

JRF:pa

cc: Mr. N. L. Stampley  
Mr. R. B. McGehee  
Mr. T. B. Conner

Dr. Ernst Volgenau, Director  
Division of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

7909270378

Member Middle South Utilities System

1046 B019 5/10 275

790204

OFFICIAL COPY