

POOR ORIGINAL

Central files

X

AUG 28 1979

REGULATORY DOCKET FILE COPY

MEMORANDUM FOR: A. Schwencer, Chief
Operating Reactors Branch No. 1
Division of Operating Reactors

FROM: V. S. Noonan, Chief
Engineering Branch
Division of Operating Reactors

SUBJECT: H. B. ROBINSON STEAM ELECTRIC PLANT, UNIT 2
SAFETY ANALYSIS OF INTERIM ACTIONS TAKEN TO
ELIMINATE FEEDWATER PIPING CRACKS

Licensee Carolina Power & Light Company
NSSS Vendor/AE: Westinghouse/Ebasco
Docket Number: 50-261
Project Manager: D. Neighbors

The Engineering Branch, DOR has reviewed the actions taken by the licensee to correct the cracking which was located in the feedwater system piping.

We find that the repair program, the nondestructive inspections and leakage testing performed following the repairs, the instrumentation and testing program implemented by the licensee and the augmented inservice inspection committed to by the licensee are adequate to ensure that the piping integrity will be maintained. Our Safety Evaluation is enclosed.

Original signed by *V. S. Noonan*

Vincent S. Noonan, Chief
Engineering Branch
Division of Operating Reactors

Enclosure: As stated

Contact: R. Hermann
49-27094

cc: D. G. Eisenhut
L. C. Shao
P. J. Knight
W. Gammill
E. Jordan
D. Neighbors
R. Klecker
T. H. Liu
J. Strosnider
W. J. Conner
W. Hazelton
R. Hermann

OFFICE	W. Hazelton	R. Hermann	EB: DOR	EB: DOR	EB: DOR
SURNAME		R. Hermann:mb	WHazelton	VSNoonan	
DATE		8/27/79	8/27/79	8/27/79	