



Duquesne Light

435 Sixth Avenue
Pittsburgh, Pa.
15219

(412) 456-8000

DUQUESNE LIGHT COMPANY
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

October 19, 1979
BVPS:JAW:728

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
LER 79-37/03L

Mr. B. H. Grier, Director of Regulation
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

In accordance with Appendix A, Beaver Valley Technical Specifications,
the following Licensee Event Report is submitted:

LER 79-37/03L, Technical Specification 3.8.2.3, Battery cell voltage drop
in excess of 0.05 volts.

Very truly yours,

J. A. Werling
J. A. Werling
Superintendent

Attachment

1208 040

1002
5/11
364
6000

7910250

Mr. B. H. Grier
October 19, 1979
BVPS:JAW:728
Page 2

cc: Director Of Management & Program Analysis ✓
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. L. Wigginton BVPS Licensing Project Manager
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. A. Beckman, Nuclear Regulatory Commission, King of Prussia, PA

G. A. Olson, Secretary, Prime Movers Committee - EEI

1208 041