

NORTHEAST UTILITIES

THE CONNECTICUT LIGHT AND POWER COMPANY
THE HARTFORD ELECTRIC LIGHT COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYoke WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

September 7, 1979

Docket No. 50-336

Mr. Boyce H. Grier, Director
Region I
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Gentlemen:

Millstone Nuclear Power Station, Unit No. 2
Startup Testing Report

Pursuant to Millstone Nuclear Power Station, Unit No. 2, Technical Specification 6.9.1.3, Northeast Nuclear Energy Company (NNECO) hereby submits the summary report of the plant startup and power escalation testing, following the Cycle 3 refueling.

As indicated in the Attachment, all startup test results met acceptance criteria and Technical Specification requirements, with the exception of the Power Coefficient measurement. The justification for this deviation, which is traceable to refinements in analytical simulation, is also provided.

We trust you find the attached report sufficient to fulfill the requirements of the Millstone Unit No. 2 Technical Specifications.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in cursive script, reading 'W. G. Council', written over a horizontal line.

W. G. Council
Vice President

Attachment

1221 163

7910290149