

October 23, 1979

FILE: NG-3514(B)

SERIAL NO.: GD-79-2680

Office of Nuclear Reactor Regulation
Attention: Mr. T. A. Ippolito, Chief
Operating Reactors Branch No. 3
United States Nuclear Regulatory Commission
Washington, D.C. 20555


BRUNSWICK STEAM ELECTRIC PLANT, UNIT NO. 2
DOCKET NO. 50-324
LICENSE NO. DPR-62
END-OF-CYCLE MCPR CORRECTION

Dear Mr. Ippolito:

On October 11, 1979, Carolina Power & Light Company (CP&L) delivered to NRC a technical specification change request dated October 10, 1979 to modify the end-of-cycle (EOC) MCPR limits to correct an error. We requested that this change be processed on an expedited basis so that the change could be in place before the (EOC-2000 MWD/t) burnup was reached. CP&L was subsequently advised by NRC via telephone that an expedited review would not be possible at this time. This letter is to inform you that the (EOC-2000 MWD/t) burnup was reached on October 15, 1979 and to confirm that the correct, more conservative MCPR limits are being used at this time and will continue to be used for the remainder of this cycle.

Please call if you have any questions.

Yours very truly,


E. E. Utley
Executive Vice President
Power Supply & Customer Services

EEU/jcb

cc: Mr. J. P. O'Reilly

1238 011

7910300 259

P

Acc'd
5/10