

LICENSEE EVENT REPORT

CONTROL BLOCK:

							(1)
--	--	--	--	--	--	--	-----

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 7 8 N C B E P 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
9 14 15 25 26 30 57 CAT 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T
0 1 7 8 R E P O R T S O U R C E L 6 0 5 0 - 0 3 2 4 7 1 0 0 3 7 9 8 1 0 2 5 7 9 9
60 61 68 69 74 75 80
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing PT 2.2.1a, Instrument System Isolation Valves Cycling test, the fol-

0 3 | lowing RIP valves failed: 1) X59B, push button stuck; 2) X61A, push button stuck;

0 4 | 3) X74A, no shut indication

0 5 | Technical Specification 3.6.3b, 6.9.1.9b

0 6 |

0 7 |

0 8 |

09		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE			
7	8	S	D	E	X	V	A	L	V	O	P	D	Z				
		9	10	11	12	13	18				19	20					
LER/RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
17	7	9	083		03		L		0								
		21	22	24	26	28	29	30	31	32							
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
B	X	Z	Z	0000		N		Y		A		X999					
33	34	35	36	37		41		42		43		44					
18	19	20	21	22		23		24		25		26					

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 On valve X74A, the limit switch was found to be out of adjustment, and was readjusted

1 1 for correct operation. The button for valve X61A was replaced and the button for valve

1 2 X59B was freed and lubricated. All valves were cycled and returned to service. An

1 3 Engineering Work Request has been generated to determine if these switch failures are

1 4 a generic problem.

7 8 9 80

FACILITY STATUS
1 5 E 28

% POWER
10 9 2 29 NA

METHOD OF DISCOVERY
E 31 Periodic Test

DISCOVERY DESCRIPTION
32

ACTIVITY CONTENT
7 8 9 Z 33

RELEASED OF RELEASE
10 11 Z 34 NA

AMOUNT OF ACTIVITY
44 45 46 NA

LOCATION OF RELEASE
36

PERSONNEL EXPOSURES
NUMBER TYPE DESCRIPTION
1 7 0 0 0 37 Z 38 NA

PERSONNEL INJURIES
NUMBER DESCRIPTION
1 8 0 0 0 40 NA

LOSS OF OR DAMAGE TO FACILITY
TYPE DESCRIPTION
1 9 Z 41 NA

PUBLICITY
ISSUED DESCRIPTION
2 0 N 42 NA

NRC USE ONLY
7 9 1 0 3 0 0 3 2 7

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521