

## LICENSEE EVENT REPORT

U.S. NUCLEAR REGULATORY COMMISSION

CONTROL BLOCK: 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 G A E I H 2 2 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5

8 9 14 15 25 26 57 CAT 58

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T  
0 1 L 6 0 5 0 0 0 0 3 6 6 7 1 0 0 8 7 9 8 1 0 2 6 7 9 9

60 61 68 69 74 75 80

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | With the reactor in the shutdown mode, while performing procedure HNP-2-3952E, Local

0 3 | Leak Rate Test, excessive leakage was found to exist at the outer door seal of the

0 4 | primary containment airlock. There should not be any detectable leakage per

0 5 | Technical Specification 4.6.1.3. Public health and safety were not affected by this

0 6 | incident. This is not a repetitive occurrence.

0 7 |

0 8 |

8 9

0 9 S A 11 E 12 E 13 P E N E T R 14 Z 15 Z 16

9 10 11 12 13 18 19 20

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

17 9 1 1 0 0 3 L 0

22 23 24 26 27 28 29 30 31 32

LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

A 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 A 25 C 3 1 0 26

33 34 35 36 37 40 41 42 43 44 47

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The excessive leakage was due to abrasions and a small laceration on the outer door

1 1 | seal. This is a normal deterioration of the seal as the airlock door is the main

1 2 | access to the primary containment. The outer door seal was replaced and procedure

1 3 | HNP-2-3952E performed satisfactorily.

1 4 |

7 8 9

1 5 G 28 0 0 0 0 29 NA B 31 Surveillance testing

7 8 9 10 11 13 44 45

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 Z 33 Z 34 NA NA NA

7 8 9 10 11 41 45

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 0 0 0 37 Z 38 NA 1281 092

7 8 9 11 12 13 41 45

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 0 0 0 40 NA NA POOR ORIGINAL

7 8 9 11 12 13 41 45

PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 Z 42 NA 7911010 439

7 8 9 11 12 41 45

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 N 44 NA NA

7 8 9 10 41 45

PUBLICITY ISSUED DESCRIPTION

NAME OF PREPARER R. T. NixPHONE: 912-367-7781

NRC USE ONLY