

LICENSEE EVENT REPORT

CONTROL BLOCK:

1	2	3	4	5	6
---	---	---	---	---	---

 (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4		5
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	--	---

7 8 9 14 15 25 26 30 57 CAT 58CON'T

0	1	R	L	6	0	5	0	-	0	3	2	4	7	0	9	1	0	7	9	8	1	0	3	0	7	9	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing PT 1.2.4, APRM High Flux and Downscale Test, the downscale alarm for

0 3 APRM "F" actuated at 2% vice the required $\geq 3\%$. APRM "B" was also out of service due

0 4 to a detector open signal lead.

0 5 Technical Specification 3.3.1, 6.9.1.9a

0 6

0 7

0 8

0	9	R	B	11	E	12	G	13	I	N	S	T	R	U	14	Y	15	Z	16	17	7	9	—	0	6	8	—	0	3	X	—	1	18	X	19	Z	20	Z	21	0	0	0	0	N	23	Y	24	N	25	G	0	8	0	0	26
---	---	---	---	----	---	----	---	----	---	---	---	---	---	---	----	---	----	---	----	----	---	---	---	---	---	---	---	---	---	---	---	---	----	---	----	---	----	---	----	---	---	---	---	---	----	---	----	---	----	---	---	---	---	---	----

7 8 9 10 11 12 13 18 19 20 21 22 23 24 26 27 28 29 30 31 32 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 APRM "F" was out of calibration due to instrument drift. The instrument was recal-

1 1 brated and returned to service satisfactorily. APRM "B" will be replaced during the

1 2 next outage of sufficient length. As this is the first APRM calibration problem, this

1 3 is considered an isolated event and no further action is required.

1	4	E	28	0	8	5	29	NA	30	B	31	Periodic Test	32	1	6	Z	33	Z	34	NA	35	NA	36	1	7	0	0	0	37	Z	38	NA	39	1	8	0	0	0	40	NA	41	1	9	Z	42	NA	43	2	0	N	44	NA	45
---	---	---	----	---	---	---	----	----	----	---	----	---------------	----	---	---	---	----	---	----	----	----	----	----	---	---	---	---	---	----	---	----	----	----	---	---	---	---	---	----	----	----	---	---	---	----	----	----	---	---	---	----	----	----

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

NAME OF PREPARER A. C. Tollison, Jr.

PHONE 7911020 401
919-457-9521

NRC USE ONLY