



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

October 11, 1979

Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street - Suite 3100
Atlanta, Georgia 30303


ATTENTION: Mr. J. P. O'Reilly, Director

Gentlemen:

SUBJECT: Grand Gulf Nuclear Station
File 0260/0498/15525/15526
Interim Report for PRD-79/14
as Defined in 10 CFR 50.55(e)
AECM-79/114

On September 7, 1979, Mississippi Power & Light Company notified Mr. J. K. Rausch of your office of a potential reportable deficiency at the Grand Gulf Nuclear Station construction site. The deficiency concerns NAMCO supplied limit switches which may not meet the safety requirements of the original purchase specification. Data is still being gathered and analyzed preparatory to determining reportability within the meaning of 10 CFR 50.55(e). Details of the latest information are described in the attached report.

Yours truly,


L. F. Dale
Nuclear Project Manager

JRF/JDR:pa
Attachment

cc: Mr. N. L. Stampley
Mr. R. B. McGehee
Mr. T. B. Conner

Mr. Victor Stello, Jr., Director
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

1292 210

Borg
5/11

7911070 431

Member Middle South Utilities System

5 OFFICIAL COPY