

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 C T M N S 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 3 6 7 0 9 0 4 7 9 8 1 1 0 2 7 9 9
7 8 60 61 63 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During routine power operation, a hydraulic snubber located on the B main steam atmos-
0 3 pheric dump valve was declared inoperable due to a broken off fluid reservoir. The
0 4 snubber was replaced. Facility operation was in accordance with Technical Specification
0 5 3.7.8.1. A second identical failure, shearing of the reservoir outlet, occurred on
0 6 10/3/79, and a replacement unit again installed. Snubber data: Hanger 405388, ITT
0 7 Grinnell, Fig. 201, 2-1/2 inch bore x 5 inch stroke.

0 8
7 8 9 80

0 9 SYSTEM CODE H B 11 CAUSE CODE E 12 CAUSE SUBCODE C 13 COMPONENT CODE S U P P O R T 14 COMP. SUBCODE D 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 7 9 21 22 23 SEQUENTIAL REPORT NO. 0 2 8 24 26 27 OCCURRENCE CODE 0 3 28 29 30 REPORT TYPE X 31 32 REVISION NO. 1
ACTION TAKEN C 18 FUTURE ACTION X 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NRPD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER I 2 0 7 26
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Original failure attributed to personnel breaking off reservoir. Subsequent failure
1 1 indicated fatigue failure of reservoir outlet nipple at thread base due to steam line
1 2 vibration. Original snubbers were old style with reservoir mounted on brackets above
1 3 unit. Replaced with new style unit with reservoir attached to snubber. Visual inspec-
1 4 tion frequency increased to 12 mths. per Tech. Spec. Table 4.7-3.

7 8 9 80

1 5 FACILITY STATUS E 23 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Operation observation 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 6 RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

2 0 PUBLICITY ISSUED Z 44 DESCRIPTION NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

NAME OF PREPARER James Crockett

PHONE: (203) 447-1791

7911070539

NRC USE ONLY

60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100