

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C B E P 1 00 - 000000 - 00 341111 45

CON'T  
01 REPORT SOURCE L 050 - 0325 7100579 8110179 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  
02 During normal operation, an attempt to start the Reactor Building Exhaust and Supply  
03 fan "C" resulted in tripping the breaker from sub-station E-5 to MCC 1XG. This motor  
04 control center supplies power to "A" SLC pump, which was declared inoperable.  
05 Technical Specification 3.1.5, 6.9.1.9b  
06  
07  
08

09 SYSTEM CODE R B 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE C K T B K R 14 COMP. SUBCODE A 15 VALVE SUBCODE Z 16  
17 LER/RO REPORT NUMBER 79 EVENT YEAR 79 SEQUENTIAL REPORT NO. 081 OCCURRENCE CODE 03 REPORT TYPE L REVISION NO. 0  
ACTION TAKEN X 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0000 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER G 080 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27  
10 The breaker was reset and MCC 1XG was re-energized. The starting and running current  
11 for the fans were checked with no abnormalities noted. This is considered an isolated  
12 event and no further action is required.  
13  
14

15 FACILITY STATUS E 28 % POWER 098 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Surveillance 32  
16 ACTIVITY RELEASED Z 33 CONTENT Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
17 PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION NA 39  
18 PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION NA 41  
19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521

7911090 495

707 252