



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

ILLUMINATING BLDG. ■ PUBLIC SQUARE ■ CLEVELAND, OHIO 44101 ■ TELEPHONE (216) 623-1350 ■ MAIL ADDRESS P. O. BOX 5000

Serving The Best Location in the Nation

Dalwyn R. Davidson
VICE PRESIDENT - ENGINEERING

October 19, 1979

Mr. James G. Keppler, Director
Region III Office of Inspection
and Enforcement
U. S. Nuclear Regulatory Commission
Glen Ellyn, IL 60137

Re: Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
IE Bulletin No. 79-23

Dear Mr. Keppler:

In accordance with your request, the following information has been provided as response to IE Bulletin 79-23. After reviewing drawings and manuals applicable to our emergency diesel generators, we have concluded that this bulletin does not apply to our facility. This is due to the fact that our system is designed with an ungrounded exciter.

Very truly yours,

Dalwyn R. Davidson
Dalwyn R. Davidson
Vice President
System Engineering and Construction

DRD/KP:pb

12/Y/1

cc: Victor Stello, Director
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, DC 20555

1310 357

OCT 24 1979

7911120 027