

Georgia Power Company
Post Office Box 4545
Atlanta, Georgia 30302
Telephone 404 522-6060



Vogtle Project

Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202
Telephone 205 870-6011

October 5, 1979

United States Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II - Suite 3100
101 Marietta Street
Atlanta, GA 30303

REFERENCE:
IE: II: MDH
50-424/79-14
50-425/79-14
File: X7BG10
Log: GM-508

Attention: Mr. C. E. Murphy

Gentlemen:

The Georgia Power Company wishes to submit the following information concerning the noncompliance discussed in your inspection report number 50-424/79-14 and 50-425/79-14.

Our response to inspection report 50-424/425/78-9 outlined the method Plant Vogtle would use for collecting concrete test samples. Quality Control personnel were trained and have implemented this method.

The proper testing procedure for concrete has been re-emphasized to the Civil Q. C. Inspection Supervisor responsible for Quality Control activities for pour Nos. A-080-135 and A-080-153. All Civil Q.C. Personnel were informed of the noncompliance and reminded of the need for studying and following all applicable procedures in the inspection of the work. Quality Assurance has increased their monitoring of concrete operations to assure that concrete sampling complies with the procedures. Full compliance to concrete placement and testing procedures was accomplished October 4, 1979.

Neither the inspection report nor this reply contain any proprietary information and may be placed in the NRC's Public Document Rooms.

Very truly yours,

Doug Dutton
Project General Manager

CWH:tp

7911120 076

790168
OFFICIAL COPY

United States Nuclear Regulatory Commission
Mr. C. E. Murphy
October 5, 1979
Page 2

xc: M. D. Hunt - Region II
J. H. Miller, Jr.
W. E. Ehrensperger
F. G. Mitchell, Jr.
C. F. Whitmer
R. J. Kelly
R. E. Conway
R. W. Staffa
C. W. Hayes
W. M. Johnston, Jr.
C. R. Miles, Jr.
D. L. McCrary
R. A. Thomas
J. A. Bailey
J. L. Leamon
H. A. Sindt
B. L. Lex
K. M. Gillespie
E. D. Groover

1311 323