

BALTIMORE GAS AND ELECTRIC COMPANY

GAS AND ELECTRIC BUILDING
BALTIMORE, MARYLAND 21203

ARTHUR E. LUNDVALL, JR.
VICE PRESIDENT
SUPPLY

January 29, 1980

Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Robert W. Reid, Chief
Operating Reactor Branch #4
Division of Operating Reactors

Subject: Calvert Cliffs Nuclear Power Plant
Units No. 1 & 2, Docket No. 50-317 & 50-318
Fire Protection Safety Evaluation Report and
Amendments to Facility Operating License
File: 013-261-0, L-037-F

- Reference:
- (1) NRC letter transmitting the SER dated September 14, 1979 from Reid to Lundvall, same subject
 - (2) BG&E letter dated September 14, 1979 from Lundvall to Reid
 - (3) NRC submittal "Comments on Test Procedures", received November 5, 1979 by telecopier from NRC Staff
 - (4) BG&E/NRC meeting November 14, 1979 at NRC offices, Phillips Building, Bethesda, Maryland
 - (5) NRC letter dated November 29, 1979 from G. Lainas to R. Reid containing comments relative to test procedures transmitted by telecopier by NRC Staff

Gentlemen:

In accordance with above references, we have revised the test procedures previously submitted by our letter dated September 14, 1979, for the qualifications of cable and pipe penetrations to reflect comments received in Reference (5). Enclosed please find the revised copy of the procedure, "Fire Test Procedure for Cable and Pipe Penetrations". The procedure provides for testing installed or existing representative types of floor and wall fire stops. In addition, other materials will be tested and evaluated simultaneously which may be utilized, if required.

We have placed an order with Southwest Research Laboratories, San Antonio, Texas to perform the tests per the enclosed specifications. The tests are scheduled to be performed during February; however, the final test results will not be available until March, 1980. We will provide the report of the test results to the NRC Staff.

1841 303


F 8001310

280

January 29, 1980

On November 6, 1979, your Mr. E. L. Conner, Jr. requested that NRC Staff be allowed to witness the tests. We will inform Mr. Conner by phone as to the date actual tests will be conducted by the Laboratory.

Very truly yours,

A handwritten signature in dark ink, appearing to read "C. H. Poindexter". The signature is fluid and cursive, with the first letters of the first and last names being capitalized and prominent.

C. H. Poindexter for
A. E. Lundvall, Jr.

cc: J. A. Biddison, Esquire
G. F. Trowbridge, Esquire
Messrs. E. L. Conner, Jr. - NRC
J. W. Brothers - Bechtel

1841 304