

### LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

5	1	A	L	J	M	F	1	2	0	0	-	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5		
7	8	9	LICENSE CODE					14	LICENSE NUMBER										25	LICENSE TYPE							30	5/ CAT 58		

0	1	REPORT SOURCE										DOCKET NUMBER										EVENT DATE										REPORT DATE																														
7	8	L	G	0	5	0	0	0	3	4	8	7	1	2	2	6	7	9	8	0	1	2	5	8	0	9																																				
		60	61										68										69										74										75										80									

0 2 At 2125 on 12/26/79, 1C charging pump was removed from an operable status to perform  
0 3 maintenance. At 0500 on 12/27/79, the Shift Foreman noted that 1A and 1B charging  
0 4 pumps were electrically and mechanically aligned to "A" Train. At 1025 on 12/27/79,  
0 5 alignment of 1B charging pump to "B" Train, electrically and mechanically, was completed.  
0 6 Tech. Spec. 6.9.1.9.c requires reporting of observed inadequacies in the implementation  
0 7 of administrative or procedural controls which threaten to cause reduction of degree of  
5 8 redundancy provided in reactor protection or ESF systems. The health and safety of the  
7 8 9 public were not affected. 8

0 9		SYSTEM CODE P C		CAUSE CODE A		CAUSE SUBCODE A		COMPONENT CODE Z Z Z Z Z Z						COMP. SUBCODE Z		VALVE SUBCODE Z	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22		
17 LER-RO REPORT NUMBER		EVENT YEAR 7 9		SEQUENTIAL REPORT NO. 0 6 8		OCCURRENCE CODE 0 3		REPL. TYPE L		REVISION NO. 0							
ACTION TAKEN H		FUTURE ACTION Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED N		NPPD-4 FORM SUB. N		PRIME COMP. SUPPLIER Z		COMPONENT MANUFACTURER Z 9 9 9	
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50

Paragraph 6.7.3 of FNP-1-AP-52, Equipment Status Control and Maintenance Authorization, was incorrectly implemented. During the course of removing 1C charging pump for maintenance, 1B charging pump was incorrectly left aligned to "A" Train, leaving no charging pump in "B" Train. The personnel involved were reinstructed on the importance of ensuring that when equipment is removed from service, there is no resulting LCO, or, if there is an LCO, it is identified.

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
1	5	E	26	1	0	0	29	NA	30	A	31	Checking isolation of IC charging pump.		
7	8	9	10	11	12	13	14	15	16	17	18	19	20	
ACTIVITY CONTENT						AMOUNT OF ACTIVITY						LOCATION OF RELEASE		
1	5	Z	33	Z	34	NA			35	NA			36	
7	8	9	10	11	12	13	14	15	16	17	18	19	20	

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	

[illegible][illegible]

7 8 9 10 11 12 NA 445

ISSUED DESCRIPTION (A1) NRC USE ONLY

7	8	9	10	11	12	13	14	15	16	17	18	19	20
Z	n	N	(M)	NA		1866	013						

NRC USE ONLY

1866-013