

CONTROL BLOCK:

--	--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	N	P	I	N	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

REPORT SOURCE: 0 1 7 8 L 6 0 5 0 0 0 2 8 2 7 1 1 2 1 7 9 8 0 1 3 0 8 0 9
60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During walkdown inspection dictated by IE Bulletin 79-14 and 79-02, two snubbers in
0 3 | the Cooling Water System were found incorrectly installed and one hanger in the
0 4 | Auxiliary Feedwater System was found damaged. One hanger each in the Cooling Water
0 5 | and Component Cooling Water Systems was found to have inadequate safety factor. No
0 6 | effect on public health and safety. Tech. Spec. 3.12 applies.
0 7 |
0 8 |

SYSTEM CODE W A (11)		CAUSE CODE B (12)		CAUSE SUBCODE C (13)		COMPONENT CODE S U P P O R T (14)				COMP. SUBCODE D (15)		VALVE SUBCODE Z (16)	
7 8		9 10		11 12		13 14 15 16 17				18 19		20 21	
(17) LER/RO REPORT NUMBER		EVENT YEAR 7 9 (22)		SEQUENTIAL REPORT NO. 0 3 0 (26)		OCCURRENCE CODE 0 3 (29)		REPORT TYPE X (31)		REVISION NO. 1 (32)			
23 24		25 26		27 28		29 30		31 32		33 34		35 36	
ACTION TAKEN B (18)		FUTURE ACTION Z (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 0 (22)		ATTACHMENT SUBMITTED N (23)		NPRD-4 FORM SUB. Y (24)	
37 38		39 40		41 42		43 44		45 46		47 48		49 50	
PRIME COMP. SUPPLIER A (25)		COMPONENT MANUFACTURER Z 9 9 9 (26)											
51 52		53 54		55 56		57 58		59 60		61 62		63 64	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	Repairs have been made. All five devices are operable. Inspection is continuing.
1	1	
1	2	
1	3	
1	4	

7 R 9

6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

FACILITY STATUS (28) E 0 6 5 (29) N/A (30) OTHER STATUS

METHOD OF DISCOVERY (31) C Inspection per IE Bulletins (32) DISCOVERY DESCRIPTION

ACTIVITY CONTENT (33) Z (34) Z (35) NA (36) LOCATION OF RELEASE

RELEASED OF RELEASE (33) Z (34) Z (35) NA (36) LOCATION OF RELEASE

AMOUNT OF ACTIVITY (35) NA (36) LOCATION OF RELEASE

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37) Z (38) NA				

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	2	0	0	0	NA

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE DESCRIPTION
1 9 Z (42) NA

PUBLICITY (45)

ISSUED		DESCRIPTION		NRC USE ONLY															
2	0	N	NA																
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26

NAME OF PREPARER A. A. Hunstad

PHONE 612-388-4767

8002040 477