



LER CONTINUATION -- RO# 2-80-17

Facility: BSEP Unit # 2

Event Date 1-18-80

by maintenance it was reviewed as a priority "4" ticket and filed accordingly. A new maintenance system, which started on January 1, 1980, now provides for two maintenance reviews of all trouble tickets when received, which should help in detecting incorrectly classified trouble tickets. A new operating instruction is being written to provide for LCO coverage on equipment found when the plant is in a condition where the component is not required, but where a change in the plant condition (mode) would require the component operable. All licensed Operations personnel will review this LER.

1927 281