

# LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	37	CAT 5H	

L	6	0	5	0	-	0	3	2	5	7	1	2	0	6	7	9	1	0	1	2	9	8	0
60	61									68	69					74	75						81
POCKET NUMBER										EVENT DATE										REPORT DATE			

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing PT 9.5, HPCI 1000# Flow Rate Test, the HPCI system isolated due to

0 3 | a high suction pressure signal from 1E41-PSH-N031 which tripped the HPCI turbine

0 4 | stop valve.

0 5 |

0 6 |

0 7 |

0 8 | Technical Specifications 3.5.1, 6.9.1.9b

SYSTEM CODE S F 11		CAUSE CODE E 12		CAUSE SUBCODE B 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE E 15		VALVE SUBCODE Z 16							
EVENT YEAR 7 9		SEQUENTIAL REPORT NO. 1 0 4		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 1									
ACTION TAKEN B 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. Y 24		PRIME COMP. SUPPLIER N 25		COMPONENT MANUFACTURER B 0 6 9	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The diaphragm on 1E41-PSH-N031 was found to be leaking, thus providing a false high  
1 1 pressure signal. The diaphragm was replaced and returned to service satisfactorily.  
1 2 This switch is checked on a quarterly basis per the calibration program. This is  
1 3 considered an isolated event and no further action is required.  
1 4

FACILITY STATUS (1) 5 (28) C (28) POWER (0) 1 3 (19) 0 NA (30) OTHER STATUS (30)  
 METHOD OF DISCOVERY (31) B (31) DISCOVERY DESCRIPTION (32) Periodic Test (32)  
 ACTIVITY CONTENT (1) 6 (33) Z (34) 2 NA (35) AMOUNT OF ACTIVITY (35)  
 RELEASED OF RELEASE (1) 6 (33) Z (34) 2 NA (36) LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	(39)
7	8	9	11	12	11				

PERSONNEL INJURIES									
NUMBER			DESCRIPTION						
1	2	3	4	5	6	7	8	9	10
0	0	0	40	NA					

1928 236

7		8		9		10	
TYPE		DESCRIPTION					
1	0	2	42	NA			

ISSUED (44) DESCRIPTION (45) NA 8002060 534 NRC USE ONLY

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521