

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C B E P 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 1 4 5
7 9 0 14 15 25 26 30 37 CAT 38

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T

REPORT SOURCE: 01 L 6 0 5 0 - 0 3 2 4 7 0 1 0 3 8 0 3 0 1 2 9 8 0 3

DOCKET NUMBER: 60 61 68 69 75 80

EVENT DATE: 14

REPORT DATE: 14

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During a normal reactor startup, control rod 26-07 had no position indication at notch 48. On a subsequent startup on January 9, 1980, control rod 34-35 had no indication at notch 7.

0 3 |

0 4 |

0 5 |

0 6 |

0 7 |

Technical Specification 3.1.3.7, 6.9.1.9b

0	9	SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE	
0	9	I	D	E		A		I	N	S	T	R	U	S	Z
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	
LEP NO. REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.					
17		8	0	0	0	6		0	3	L	0				
21	22	23	24	25	26	27	28	29	30	31	32				
ACTION TAKEN		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		PRIME COMP. SUPPLIER					
X	X	Z	Z					N	Y	N	G				
33	34	35	36	37	38	39	40	41	42	43	44				

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 3 | The problem is believed to be faulty reed switches in the PIP probes. These problems

1 1 | will be corrected during the next outage of sufficient length for a drywell entry.

1 2 | Engineering is evaluating these switches to determine if a generic problem exists.

1 3 |

1 4 |

FACILITY STATUS: 1 5 C 28
 POWER: 0 0 2 29
 OTHER STATUS: 30 N/A
 METHOD OF DISCOVERY: A 31
 DISCOVERY DESCRIPTION: 32 Operator Surveillance

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 2 33 34

AMOUNT OF ACTIVITY (35)
N/A

LOCATION OF RELEASE (36)
N/A

PERSONNEL EXPOSURES		TYPE		DESCRIPTION
NUMBER				
1	7	0	0	0
		37	Z	38
				N/A

PERSONNEL INJURIES		NUMBER		DESCRIPTION		DATE	
1	2	3	4	5	6	7	8
		0	0	0	(40)	N/A	1927 271

8 9		11 12		1721 271	
LOSS OF OR DAMAGE TO FACILITY				(43)	
TYPE		DESCRIPTION			
1	9	2	(42)	N/A	

7 8 9 10 80

PUBLICITY

ISSUED DESCRIPTION (45)

2 3 N 44 N/A 8002060 622 NRC USE ONLY

NAME OF PREPARER A. C. Tollison, Jr.

PHONE (919) 457-9521