

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | A | R | A | N | 0 | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 30 37 CAT 58

CON'T

01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 0 | 7 | 1 | 2 | 0 | 6 | 7 | 8 | 8 | 0 | 1 | 0 | 5 | 7 | 9 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | During Low Power Physics Testing, Mode 2 operation, CEA's
03 | 26, 1, 48, 46, 57, & 52 dropped and CEA's 22, 27, and 29
04 | slipped while moving for positioning as required by testing
05 | over an eleven day period. The individual CEA misalignments
06 | caused no consequences as the reactor power was less than 1%.
07 | There have been no similar occurrences. Reported per T.S.
08 | 6.9.1.9.b.

09 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE
7 8 9 10 11 12 13 14 15 16
R B 11 E 12 G 13 C R D R V E 14 Z 15 Z 16

17 | LER/RO REPORT NUMBER | 7 | 8 | SEQUENTIAL REPORT NO. | 0 | 2 | 3 | OCCURRENCE CODE | 0 | 3 | REPORT TYPE | L | REVISION NO. | 0 |
21 22 23 24 25 26 27 28 29 30 31 37

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
33 34 35 36 37 40 41 42 43 44 47
A 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 N 25 C 4 9 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | CEA's 26, 1, 48, 46, 57, 22, & 52 most probably dropped or
11 | slipped due to timer card failures. CEA's 27 & 29 failed
12 | due to sequencer card failures. Repairs were made subsequent
13 | to each failure
14 |
15 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION
7 8 9 10 11 12 13 14 15 16
B 28 0 0 0 29 Low Power Phy. A 31 NA
Test

16 | ACTIVITY CONTENT | RELEASED OF RELEASE | AMOUNT OF ACTIVITY | LOCATION OF RELEASE
7 8 9 10 11 12 13 14 15 16
Z 33 Z 34 NA 35 NA 36

17 | PERSONNEL EXPOSURES | TYPE | DESCRIPTION
7 8 9 10 11 12 13
0 0 0 37 Z 38 NA 39

18 | PERSONNEL INJURIES | NUMBER | DESCRIPTION
7 8 9 10 11 12 13
0 0 0 40 NA 41

19 | LOSS OF OR DAMAGE TO FACILITY | TYPE | DESCRIPTION
7 8 9 10 11 12 13
Z 42 NA 43

20 | PUBLICITY | ISSUED | DESCRIPTION
7 8 9 10 11 12 13
N 44 NA 45

NAME OF PREPARER Chris N. Shively PHONE: 501 - 968-2519

NRC USE ONLY

7901150083