

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M A P P S 1 2 0 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 - 0 2 9 3 7 1 2 3 0 7 8 8 0 1 2 2 7 9 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 On December 30, 1978, while operating in full flow test to stir up the condensate
0 3 storage tanks'sediment, the HPCI tripped. Immediate investigation revealed a low
0 4 level in the oil sump and the overflow pit around the turbine filled with oil. The
0 5 HPCI was declared INOP and operability of backup systems was demonstrated immediately
0 6 as required by T.S. 4.5.c.2. Public Health and Safety were not affected.
0 7
0 8

0 9
7 8 9

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
S F 11 E 12 B 13 P 1 P E X X 14 A 15 Z 16
7 8 9 10 11 12 13 18 19 20
17 LER RO REPORT NUMBER EVENT YEAR 7 8 21 22 SEQUENTIAL REPORT NO. 0 5 7 24 26 OCCURRENCE CODE 0 3 28 29 REPORT TYPE L 30 31 REVISION NO. 0 32
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHODG HOURS 22 ATTACHMENT SUBMITTED N 23 NPD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER T 1 4 7 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 Maintenance Personnel discovered the fitting for the discharge pressure gage on the
1 1 attached oil pump was disconnected. The fitting was reconnected and surveillance
1 2 8.5.4.1 (HPCI Pump Operability and Flow Rate Test at 1000 PSIG) was completed satis-
1 3 factorily and the HPCI was returned to service.
1 4

1 5
7 8 9

FACILITY STATUS E 28 1 0 0 29 OTHER STATUS 30 N.A. METHOD OF DISCOVERY A 31 Operational Event DISCOVERY DESCRIPTION 32
7 8 9 10 12 13 44 45 46 80

ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY 35 N.A. LOCATION OF RELEASE 36
7 8 9 10 11 44 45 80

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION 39 N.A.
7 8 9 11 12 13 80

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION 41 N.A.
7 8 9 11 12 80

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION 43 N.A.
7 8 9 10 80

PUBLICITY ISSUED N 44 DESCRIPTION 45 N.A.
7 8 9 10 80

2 0 N 44
7 8 9 10 80

NAME OF PREPARER Charles J. Mathis

PHONE: 617-746-7900

7901260185

NRC USE ONLY