

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

0 1 M A P P S 1 2 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

On January 7, 1979 the Reactor Building Vent Monitor (RBV) was removed from service to investigate a low flow condition. The monitor was out of service for approximately two hours while I&C personnel cleaned and re-adjusted the controller. A controlled shutdown was initiated as required after the monitor was INOP for one hour and terminated when the monitor was returned to service. Public Health and safety were not affected by this event.

0 8 | _____ 80

7 8 9 10 11 12 13 14 15 16 17 18 19 20

0 9 M C E E I N S T R U C Z

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

(17) LER/RO REPORT NUMBER 7 9 —

EVENT YEAR —

SEQUENTIAL REPORT NO. 0 0 2 /

OCCURRENCE CODE 0 3

REPORT TYPE L —

REVISION NO. 0

ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPR-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER										
33	18	34	19	35	20	36	21	37	0	0	0	0	40	41	N	23	42	N	24	43	N	25	44	B	4	4	5	45

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 This event was caused by a dirty controller which was cleaned and re-adjusted.

1 1 The existing alarm system is adequate to detect problems of this nature,

1 2 therefore, no future action is contemplated.

1 3

14

FACILITY STATUS (E) (28) % POWER (1) (0) (0) (29) OTHER STATUS (30) N.A. METHOD OF DISCOVERY (A) (31) DISCOVERY DESCRIPTION (32) Operational Event

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z 33 Z 34

7 8 9 10 11

AMOUNT OF ACTIVITY (35) N.A.

LOCATION OF RELEASE (36) N.A.

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	37	Z	38	N.A.	

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	N.A.

		LOSS OF OR DAMAGE TO FACILITY		
		TYPE	DESCRIPTION	(43)
1	9	Z	(42) _____	N.A.

PUBLICITY
 ISSUED DESCRIPTION (45)
 20 N (44) 7902090315 N.A.
 NRC USE ONLY

NAME OF PREPARER Charles J. Mathis

PHONE: 617-746-7900

NRC USE ONLY

5. PO 917-926

INTERIM REPORT

Accession No. 7902010001

Contract Program or Project Title:

Water Reactor Safety Research

Subject of this Document:

Papers presented at 6th WRSR Information Meeting, Nov. 6-9, 1978.
Meeting agenda attached.

Type of Document:

Papers presented at 6th Water Reactor Safety Research Information Meeting, November 6-9, 1978 at the National Bureau of Standards

Author(s):

See agenda

Date of Document:

November 6-9, 1978

Responsible NRC Individual and NRC Office or Division:

Stanley A. Szawlewicz, Division of Reactor Safety Research

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

Prepared for
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

INTERIM REPORT