

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M A P P S 1 2 0 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 REPORT SOURCE L 6 0 5 0 - 0 2 9 3 7 0 1 2 0 7 9 8 0 2 1 2 7 9 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 On January 20, 1979 at 1220 hours, the Plant Stack Process Radiation Monitoring
0 3 System failed as indicated by "Ai/Lo Suction Flow to Stack Gas Sample Pump" an-
0 4 nunciation in the Control Room. Repairs were instituted immediately and when after
0 5 one hour repairs had not been completed, a controlled shutdown was initiated as
0 6 required by T.S. and terminated when the sample system was returned to service.

0 7
0 8
7 8 9 80

0 9 SYSTEM CODE M C 11 CAUSE CODE C 12 CAUSE SUBCODE Z 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE R 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 7 9 21 22 23 24 26 27 28 29 30 31 32
ACTION TAKEN B 18 FUTURE ACTION F 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER G 0 8 0 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 Investigation revealed the sample line was frozen. The sample line was freed with
1 1 heat and system returned to normal. Heat tape has been applied to the sample line
1 2 to prevent future occurrences.

1 3
1 4
7 8 9 80

1 5 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS N.A. 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operational Event 32
7 8 9 10 12 13 44 45 46 80

1 6 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY N.A. 35 LOCATION OF RELEASE N.A. 36
7 8 9 10 11 44 45 80

1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION N.A. 39
7 8 9 10 11 12 13 80

1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION N.A. 41
7 8 9 10 11 12 80

1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION N.A. 43
7 8 9 10 80

2 0 PUBLICITY ISSUED N 44 DESCRIPTION N.A. 45
7 8 9 10 80

7902260410

NRC USE ONLY

NAME OF PREPARER Charles J. Mathis

PHONE: 617-746-7900

617-746-7900