

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	-	0	3	4	6	7	0	3	0	6	7	9	8	0	3	1	6	7	9	9
60	61								68	69						74	75							80
DOCKET NUMBER										EVENT DATE							REPORT DATE							

During a valve lineup on 3/6/79, an Auxiliary Operator (AO) mistakenly closed Borated

Water Storage Tank (BWST) Isolation Valves DH7A and DH7B. The AO returned and informed

the Reactor Operator (RO) that he had closed DH7A and DH7B. The RO realizing that

closing DH7A and DH7B placed the unit in violation of a Tech Spec, immediately opened

DH7A and DH7B, removing the unit from the violation. There was no danger to the health

and safety of the public or station personnel. A safety actuation signal from the

Safety Features Actuation System would have opened DH7A and DH7B. (NP-32-79-02)

7	8	9	SYSTEM CODE		CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE		COMP. SUBCODE	VALVE SUBCODE							
0	9		S	F	A	B	V	A	L	V	E	X	E	D			
7		8	9	10	11	12	13		18	19		20					
(17) LER/RO REPORT NUMBER			EVENT YEAR			SEQUENTIAL REPORT NO.			OCCURRENCE CODE		REPORT TYPE		REVISION NO.				
			7	9	—	0	2	9	/	0	1	T	—	0			
			21	22	23	24		26	27	28		29	30	31	32		
ACTION TAKEN		FUTURE ACTION	EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER		
X	Z	Z	Z	Z	Z	Z	0	0	0	0	Y	Y	N	Z	Z	Z	Z
27	18	19	35	20	36	21	37		40	41	23	42	24	43	25	44	26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

This incident was caused by personnel error. An operator mistakenly closed BWST outlet

valves DH7A and DH7B instead of BWST to Borated Water Recirculation Pump 1-1 Valve BW 7.

At 0415 hours, the RO discovered that both DH7A and DH7B were closed and immediately

opened them from the Control Room. Disciplinary action was taken against the AO.

1 4 7 8 9
FACILITY STATUS 30
% POWER 29 NA
OTHER STATUS 32
METHOD OF DISCOVERY 31 Operator Observation
1 5 E 28 0 8 6 29 NA 44 45 46 32

ACTIVITY CONTENT RELEASED OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)

1 6 Z (33) Z (34) NA NA

PERSONNEL EXPOSURES									
NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	(37)	Z	(38)	NA	

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)

1 9 Z (42) NA

PUBLICITY
 ISSUED DESCRIPTION (45)
 2 0 N (44) NA 7903230162
 7 8 9 10 68 69 80

NRC USE ONLY

7903230162

419-259-5000, Ext. 276

DVR 79-046

NAME OF PREPARER

David H. Brown

PHONE _____

419-259-5000, Ext. 276