

[illegible]

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	C	B	E	P	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5	
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

REPORT SOURCE: 01 60 61 05 01 03 24 70 51 07 98 06 07 79 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing PT 20.3, Primary Containment Isolation Valve Local Leak Rate Test,

0 3 | on Unit 2, it was discovered that four MSIV's - 2B21-F022 A & D and -F028 A & D, ex-

0 4 | ceeded the allowed leakage rate of 11.5 SCFH. These valves would not hold pressure.

0 5 | Technical Specification 3.6.1.2c and 6.9.1.9b

0 6 |

0 7 |

0 8 |

0 9		SYSTEM CODE C D		11	CAUSE CODE E		12	CAUSE SUBCODE X		13	COMPONENT CODE V A L V E X					14	COMP SUBCODE F		15	VALVE SUBCODE D		16	
17		LER/RO REPORT NUMBER		EVENT YEAR 7 9		23		SEQUENTIAL REPORT NO. 0 3 1		26		OCCURRENCE CODE 0 3		29		REPORT TYPE L		31		REVISION NO. 0		32	
ACTION TAKEN X		FUTURE ACTION Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		27		ATTACHMENT SUBMITTED N		23		NFRD-4 FORM SUB. Y		PRIME COMP. SUPPLIER N		COMPONENT MANUFACTURER R 3 4 0		26	
33		34		35		36		37		40		41		42		43		44		47			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 All four valves were disassembled and cleaned. The disks of F022 A & D were found to

1 1 have cracks in the stellite. These disks were replaced from stock, and all valve

1 2 seats were lapped. The valves were reassembled and tested satisfactorily. Testing

1 3 will be continued in accordance with 10CFR50 and the Technical Specifications.

1 4

8		9		FACILITY STATUS				% POWER				OTHER STATUS (30)				METHOD OF DISCOVERY				DISCOVERY DESCRIPTION (32)				80	
1	5	H	(28)	0	0	0	(29)	NA	B	(31)	Periodic Test										80				
8		9		ACTIVITY CONTENT				RELEASED OF RELEASE				AMOUNT OF ACTIVITY (35)				LOCATION OF RELEASE (36)				80					
1	6	Z	(33)	Z	(34)	NA										NA				80					
8		9		PERSONNEL EXPOSURES				NUMBER				TYPE				DESCRIPTION (39)				80					
1	7	0	0	0	(37)	(38)	NA										2285 104				80				
8		9		PERSONNEL INJURIES				NUMBER				DESCRIPTION (41)								80					
1	8	0	0	0	(40)	NA														80					
8		9		LOSS OF OR DAMAGE TO FACILITY				TYPE				DESCRIPTION (43)								80					
1	9	Z	(42)	NA										7906120424				80							
8		9		PUBLICITY				ISSUED				DESCRIPTION (45)				NRC USE ONLY				80					
2	0	N	(44)	NA														80							

7906120424

NRC USE ONLY

A. C. Tollison, Jr.

919-457-6701