

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 3900

FILE: ENVIRO

FROM: Metropolitan Edison Company Reading, Pennsylvania 19603 Thomas A. Jenckes		DATE OF DOC 4-29-74		DATE REC'D 5-2-74		LTR X	MEMO	RPT	OTHER
TO: Mr. Muller		ORIG 1 signed		CC	OTHER	SENT AEC PDR X SENT LOCAL PDR X			
CLASS	UNCLASS XXXXX	PROP INFO	INPUT	NO CYS REC'D 1		DOCKET NO: 50-289			
DESCRIPTION: Ltr furnishing info regarding items agreed upon at the 4-8-74 meeting at Bethesda, relating to Appendix B, Enviro Tech Specs for the Three Mile Island Unit # 1.....					ENCLOSURES: <div style="border: 1px solid black; padding: 10px; text-align: center;"> Do Not Remove ACKNOWLEDGED </div>				
PLANT NAME: Three Mile Island Unit # 1									

FOR ACTION/INFORMATION

5-8-74

AB

BUTLER(L) W/ Copies	SCHWENCER(L) W/ 1 Copies (Info)	ZIEMANN(L) W/ Copies	REGAN(E) W/ 1 Copies
CLARK(L) W/ Copies	STOLZ(L) W/ Copies	DICKER(E) W/ Copies	W/ Copies
PARR(L) W/ Copies	VASSALLO(L) W/ Copies	KNIGHTON(E) W/ Copies	W/ Copies
KNIEL(L) W/ Copies	PURPLE (L) W/ Copies	YOUNGBLOOD(E) W/ Copies	W/ Copies

INTERNAL DISTRIBUTION

<u>REG FILE</u> AEC PDR OGC, ROOM P-506A MUNTZING/STAFF CASE GIAMBUSSO BOYD MOORE (L)(BWR) DEYOUNG(L)(PWR) SKOVHOLT (L) GOLLER(L) P. COLLINS DENISE REG OPR FILE & REGION(3) MORRIS STEELE	<u>TECH REVIEW</u> HENDRIE SCHROEDER MACCARY KNIGHT PAWLICKI SHAO STELLO HOUSTON NOVAK ROSS IPPOLITO TEDESCO (2) LONG LAINAS BENAROYA VOLMER	DENTON GRIMES GAMMILL KASTNER BALLARD SPANGLER <u>ENVIRO</u> MULLER DICKER KNIGHTON YOUNGBLOOD REGAN PROJECT LDR ST. MARY HARLESS	<u>LIC ASST</u> DIGGS (L) GEARIN (L) GOULBOURNE (L) LEE (L) MAIGRET (L) REED (E) SERVICE (L) SHEPPARD (L) SLATER (E) SMITH (L) TEETS (L) WADE (E) WILLIAMS (E) WILSON (L)	<u>A/T IND</u> BRAITMAN SALTZMAN B. HURT <u>PLANS</u> MCDONALD DUBE w/Input <u>INFO</u> C. MILES B. KING (E/W-358) KLECKER EISENHUT 1459 288 780
--	--	---	---	---

7910240

EXTERNAL DISTRIBUTION

1 - LOCAL PDR Harrisburg, Pa. 1 - TIC (ABERNATHY) 1 - NSIC(BUCHANAN) 1 - ASLB 1 - P. R. DAVIS (AEROJET NUCLEAR) 16 - CYS ACRS HOLDING	(1) 62X10-2 NATIONAL LAB'S ANL 1-ASLEP(E/W Bldg, Rm 529) 1-W. PENNINGTON, Rm E-201 GT 1-CONSULTANT'S NEWMARK/BLUME/AGBABIAN 1-GERALD ULRICKSON...ORNL 1-B & M SWINEBROAD, Rm E-201 GT	1-PDR-SAN/LA/NY 1-GERALD LELLOUCHE BROOKHAVEN NAT. LAB 1-AGMED(Ruth Gussman) RM-B-127, GT. 1-RD..MULLER..F-309 GT
--	--	--



METROPOLITAN EDISON COMPANY

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603

TELEPHONE 215 - 929-3601

April 29, 1974

Mr. Daniel Muller
Asst. Dir. for Environmental Projects
Directorate of Licensing
U. S. Atomic Energy Commission
Washington, D. C. 20545

50 - 289



Dear Mr. Muller:

This is a letter of confirmation of items agreed upon at the April 8, 1974, meeting at Bethesda, Maryland, between representatives of the Metropolitan Edison Company, Mr. Francis A. St. Mary, Mr. Phil Stoddard, Mr. Chuck Burke, Mr. Morris Milligan, and Mr. Pete Strom, (AEC DOL). The meeting concerned Appendix B, Environmental Technical Specifications for Three Mile Island Nuclear Station, Unit 1.

1. p. 18, para. A. -- The Sr-89 composite analysis is to be accomplished on a quarterly basis in conjunction with the Sr-90 analysis.
2. Change p. 26, para. H. to read "When the release rate of radioactive materials in gaseous waste,....."
3. p. 28, para. D. should now read:

Gas	Monthly (3)	Individual Gamma Emitters	10^{-4} uCi/cc
	Monthly	H-3	10^{-6} uCi/cc
Charcoal	Weekly (4)	I-131	10^{-12} uCi/cc
	One Weekly Sample per Month (4)	I-133, I-135	10^{-10} uCi/cc

1459 289



3800


Particulates Monthly Composite of the Samples for the Month	Individual Gamma Emitters (includ- ing Be-140, La-140, I-131)	10^{-11} uCi/cc
Quarterly Com- posite of Samples for the Quarter	Sr-89, 90	10^{-11} uCi/cc

4. p. 34 Bases, line 15 -- "2 percent of Specification b above.....", should be changed to "4 percent....." to agree with the Specification h. on p. 27 which is actually 4 percent of Specification b.

According to our understanding, the above items are to be accomplished as specifications until such time as a revision to the Environmental Technical Specifications is effected to bring our specifications in line with the standardized Environmental Technical Specifications as directed by the Directorate of Licensing, Radiological Assessment Branch.

Thank you for your attention to this matter.

Sincerely,



Thomas A. Jenckes
Staff Health Physicist

TAJ:eg

cc: R. S. Brown
J. J. Colitz
D. N. Grace
J. G. Herbein
R. F. Jones

1459 290

File 20.1.1/7.7.4.3.6.1