



METROPOLITAN EDISON COMPANY

POST OFFICE BOX 542 READING, PENNSYLVANIA 19603

TELEPHONE 215 - 929-3601

April 29, 1974

Mr. Daniel Muller
Asst. Dir. of Environmental Projects
Directorate of Licensing
U. S. Atomic Energy Commission
Washington, D. C. 20545

Dear Mr. Muller:

In the course of clarifying the intent of the Environmental Technical Specifications with the AEC staff, several questions arose from Metropolitan Edison plant staff. On April 8, 1974, a meeting between Metropolitan Edison personnel and Regulatory personnel resolved the following points:

1. Metropolitan Edison will meet all the objectives of the Environmental Technical Specifications if all of the specifications in the Environmental Technical Specifications are met.
2. Metropolitan Edison Company would like to change the radiological waste monitoring Sr-89 frequency of analysis to a frequency consistent with the Sr-90 analysis.
 - a. Table 1, p. 18, para. A. Met-Ed proposes to change the Sr-89 analysis from a monthly composite to a quarterly composite analysis.
 - b. Table 2, p. 28, para. D. Particulates: Met-Ed proposes to change the Sr-89 analysis from a monthly composite to a quarterly composite analysis.

Thank you for your attention and assistance.

Very truly yours,

Thomas A. Jenckes

Thomas A. Jenckes
Staff Health Physicist

TAJ:eg

1459 291

cc: R. S. Brown
J. J. Colitz
D. N. Grace
J. G. Herbein
R. F. Jones
File 20.1.1/7.7.4.3.6.1

7910240 783