NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

# LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | A R A N O 2 (2) | 0 0 - 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 8 (7) | 1 2 2 7 7 8 (8) | 0 1 2 5 7 9 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Mode 1 operation, during Main Turbine roll, Main Steam relief valves
03 | 2PSV1053 lifted, due to steam dump valve failures, and failed to reseat,
04 | causing excessive RCS cooldown (See also LER 50-368/78-29). The Reactor
05 | was manually tripped at 1°F below the 525°F Tave as required by
06 | T.S.3.1.1.5. No similar occurrences. Reportable per T.S.6.9.1.9(b).
07 |
08 |

09 | SYSTEM CODE C B (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 8 — SEQUENTIAL REPORT NO. 0 3 0 — OCCURRENCE CODE 0 3 — REPORT TYPE L — REVISION 00

ACTION TAKEN E (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT A (20) | SHUTDOWN METHOD B (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB N (24) | PRIME COMP SUPPLIER N (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The relief valve reseated after >1 hour of blowdown. The Reactor
11 | was manually tripped and brought to Mode 3 conditions as required by
12 | Action Statement T.S.3.1.1.5.
13 |
14 |

15 | FACILITY STATUS B (28) | % POWER 0 0 8 (29) | OTHER STATUS (30) Power Ascension | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) NA

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 | NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES
18 | NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43)
19 | TYPE Z (42) | DESCRIPTION NA

PUBLICITY
20 | ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

NAME OF PREPARER Chris N. Shively PHONE: 501/968-2519

79013100 4/5