



Duquesne Light

435 Sixth Avenue
Pittsburgh, Pennsylvania
15219

(412) 471-4300

DUQUESNE LIGHT COMPANY
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

January 26, 1979
BVFS:JAW:629

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
LER 78-65/03L

Mr. B. H. Grier, Director of Regulation
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

In accordance with Appendix A, Beaver Valley Technical Specifications,
the following Licensee Event Report is submitted:

LER 78-65/03L, Technical Specification 4.7.7.1.d.3, Inability of control
room emergency habitability system to maintain control room at $\geq 1/8$ inch above
the outside atmosphere.

Very truly yours,

J. A. Werling
J. A. Werling
Superintendent

Attachment

79013100 46

A002
5/11

Mr. B. H. Grier
January 26, 1979
BVPS:JAW:629
Page 2

cc: Director Of Management & Program Analysis ✓
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. L. Wigginton, BVPS Licensing Project Manager
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. A. Beckman, Nuclear Regulatory Commission, King of Prussia, PA

G. A. Olson, Secretary, Prime Movers Committee - EEI