

### LICENSEE EVENT REPORT

CONTROL BLOCK: 

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 C T M N S 2 2 0 0 - 0 0 0 c 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

REPORT SOURCE L 6 0 5 0 0 0 3 3 6 7 1 2 2 7 7 8 8 0 1 2 5 7 9 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing surveillance, service water isolation valve 2-SW-3.2A failed

0 3 to close. This valve isolates non vital turbine building closed cooling water

0 4 loads in the event of a safety injection actuation signal (SIAS). The actuating

0 5 air solenoid valve was replaced, the pneumatic tubing was cleaned, associated

0 6 items lubricated and the valve restored to service. The isolation valve for the

0 7 redundant service water header was operable.

[illegible]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The apparent cause of failure was the valve not functioning due to actuating air

1 1 flow being blocked. The solenoid valve is ASCO Model 834481 125 VDC. The redundant

1 2 header solenoid actuator will be inspected during the refueling outage scheduled

1 3 in March, 1979.

1	4											80			
7	8	9											80		
FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION			80
1	5		28	1	0	0	29	NA	B	31	Surveillance Test			80	
7	8	9	10	11	12	13	14	15	16				80		
ACTIVITY			CONTENT			AMOUNT OF ACTIVITY			LOCATION OF RELEASE			80			
1	6		Z	33	Z	34	NA	NA					80		
7	8	9	10	11	12	13	14	15				80			
PERSONNEL EXPOSURES			NUMBER			TYPE			DESCRIPTION			80			
1	7		0	0	0	37	Z	38	NA			80			
7	8	9	10	11	12	13	14				80				
PERSONNEL INJURIES			NUMBER			DESCRIPTION						80			
1	8		0	0	0	40	NA					80			
7	8	9	10	11	12						80				
LOSS OF OR DAMAGE TO FACILITY			TYPE			DESCRIPTION						80			
1	9		Z	42	NA						80				
7	8	9	10									80			
PUBLICITY			ISSUED			DESCRIPTION			NRC USE ONLY			80			
2	0		N	44	NA			7902050199			80				
7	8	9	10									80			

NRC USE ONLY

W. J. McCann

447-1791