NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | I L D R S 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 3 7 (7) | 0 1 0 3 7 9 (8) | 0 1 3 1 7 9 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During steady state operation the torus level increased to -1 inch, due to re-
03 petitive starts of the HPCI turbine. See RO#79-2/01T-0. Immediate operator action
04 was to pump the excess torus water to the hotwell, restoring water level to -3.5"
05 which is within specifications. This event had minimal safety significance since
06 the 0.5 inch excess in water level did not significantly affect the pressure sup-
07 pression capability. This event has occured previously at Dresden. (Unit 2 RO#75-51).
08 T.S. req's level maintained between -1.5 and -4.75" at 1# D/P.

09 SYSTEM CODE S A (11) | CAUSE CODE D (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 9 | — | SEQUENTIAL REPORT NO. 0 0 1 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN G (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Increase in the torus water level was determined to be an inadequate procedure. The
11 HPCI surveillance will be changed to include a "CAUTION" statement so the torus level
12 will not exceed specifications during repetitive starts of the HPCI turbine. No
13 further action is necessary.
14

15 FACILITY STATUS E (28) | % POWER 0 9 5 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY: TYPE Z (42) | DESCRIPTION (43) NA

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA

7902060219

NRC USE ONLY

NAME OF PREPARER M. Korchynsky PHONE: X-422