

CONTROL BLOCK: | | | | • | | ① (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1	L	6	0	5	0	0	0	2	3	7	7	0	1	0	5	7	9	3	0	1	3	1	7	9	9
7	8	60	61	DOCKET NUMBER						68	69	EVENT DATE						74	75	REPORT DATE						80

0 2 While performing Surv. DIS 1400-3, PS 2-1430-1466D tripped at 105PSI incr. Two
0 3 subsequent loadings revealed trips at 101PSI. T.S. 4.5.A and Table 3.2.2 requires
0 4 trip at 50 <=/= pr <=/= 100 psig. Dresden setpt. is 95+/- 5 psig. Safety significance
0 5 minimal, three redundant core spray pp. discharge press sw.'s were operable and would
0 6 have provided necessary permissive at 95.8 psig. Similar occurrence ref. in R.O. #
0 7 78-031/03L-0.

0 3		7 8 9		SYSTEM CODE		CAUSE CODE		CAUSE SUBCODE		COMPONENT CODE				COMP. SUBCODE		VALVE SUBCODE	
0 9		7 8		S F (11)		E (12)		E (13)		I N S T R U (14)				E (15)		Z (16)	
7 8 9		9 10		11 12		12 13		13 14 15 16 17 18				19 20		21 22		23 24	
LER RO REPORT NUMBER		EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE		REPORT TYPE		REVISION NO.							
(17) 7 9		7 9		0 0 3		0 3		L		0							
21 22		23 24		25 26		27 28		29 30		31 32							
ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS		ATTACHMENT SUBMITTED		NFR-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTURER	
E (18) Z (19)		Z (20)		Z (21)		0 0 0 9		N (22)		N (23)		N (24)		N (25)		S 3 8 2 (26)	
33 34		35 36		37 38		39 40		41 42		43 44		45 46		47 48		49 50	

1 0 Cause attributable to instrument drift. Switch was immediately reset to 94.2 psig

1 1 incr. and tested for repeatability. The Core Spray Pump Auto Blowdown Permissive

1 2 Pressure Switches will continue to be tested monthly per DIS 1400-3. Switch is mfd. by

1 3 Static-O-Ring model #5N-AA3.

1 4		7 8 9		FACILITY STATUS		% POWER		OTHER STATUS (30)		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION (32)	
1	5	E	(23)	0	9	3	(29)	NA		B	(31)	Surveillance Testing	

ACTIVITY CONTENT
RELEASED OF RELEASE
1 6 Z 33 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

PERSONNEL EXPOSURES									
NUMBER		TYPE		DESCRIPTION		(39)			
1	7	10	0	0	(37) Z	(38)	-	NA	

PERSONNEL INJURIES	DESCRIPTION
41	

[illegible]

1	3	Z	42	DESCRIPTION	NA	43
---	---	---	----	-------------	----	----

8 9 10 80

PUBLICITY

ISSUED DESCRIPTION (45)

2 0 N (44) NA 7902060 244 NRC USE ONLY

7 8 9 10 68 69 80

NAME OF PREPARER: Carl Lindberg

PHONE:

289