



Duquesne Light

435 Sixth Avenue
Pittsburgh, Pennsylvania
15219

(412) 471-4300

DUQUESNE LIGHT COMPANY
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

January 30, 1979
BVPS:JAW:630

Beaver Valley Power Station, Unit No. 1
Docket No. 50-334, License No. DPR-66
LER 78-66/03L


Mr. B. H. Grier, Director of Regulation
United States Nuclear Regulatory Commission
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

In accordance with Appendix A, Beaver Valley Technical Specifications,
the following Licensee Event Report is submitted:

LER 78-66/03L, Technical Specification 3.4.6.1, Both containment sump
pumps inoperable.

Very truly yours,


J. A. Werling
Superintendent

Attachment

7902060282

A002
5/11
5

Mr. B. H. Grier
January 30, 1979
BVPS:JAW:630
Page 2

cc: Director Of Management & Program Analysis
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. L. Wigginton, BVPS Licensing Project Manager
United States Nuclear Regulatory Commission
Washington, D. C. 20555

D. A. Beckman, Nuclear Regulatory Commission, King of Prussia, PA

G. A. Olson, Secretary, Prime Movers Committee - EEI